SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: **DOWSIL™ 121 Silicone Structural Glazing Sealant**

Submitted by:

Dow Silicones Corporation
2200 W. Salzburg Rd.
Midland, MI 48686
AHlinka@dow.com
dow.com/construction

Test Results

ATSM C719	Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Yes Extension: +25% Compression: -25% Substrate: Unprimed Glass, Unprimed Anodized Aluminum, Anodized Aluminum [Aluminum with DOWSIL 1200 OS Primer and Kynar primed with DOWSIL Primer-C OS]
Validation Date:	2/24/2025
Expiration Date:	2/23/2030
Lab Details:	PRI Construction Materials Technologies LLC 6408 Badger Drive Tampa, FL 33610 Phone: 813.621.5777 Fax: 813.621.5840