SWR Institute
400 Admiral Blvd
Kansas City, MO 64106
816.472.7974
info@swrionline.org

Product Name: DOWSIL™ 983 Silicone Structural Sealant

Submitted by:

Dow Silicones Corporation
2200 W. Salzburg Rd.
Midland, MI 48686
Ahlinka@Dow.com
dow.com/construction

Test Results

ASTM C719	Sealants Under Cyclic Movement [Hockman Cycle]; Pass: Yes Extension: +25% Compression: -25% Substrate: Unprimed Glass, Unprimed Anodized Aluminum, Anodized Aluminum [Primed with DOWSIL 1200 OS], Kynar [Primed with DOWSIL Primer C-OS]
Validation Date:	2/5/2026
Expiration Date:	2/4/2031
Lab Details:	Interek 130 Derry Court York, PA 17406 Phone: 717.764.7700 Fax: 717.764.4129